





Alliance
Fire Protection Services, Inc.

6100 GA Hwy 20 Loganville, GA 30052

GA State License# 2167B

Ph: 770.554.5004

- | System Check List | | | | | |
|---|----|----|----|-----------|--------------------------|
| | #1 | #2 | #3 | Comments: | Does Hood Need Cleaning: |
| 1. All appliances have proper nozzle coverage | S | un | S | un | T |
| 2. Duct & Plenum covered with correct nozzle | S | un | S | un | N |
| 3. System installed in accordance with Mfg. UL listing | S | un | S | un | |
| 4. Hood/Duct penetrations all sealed with weld or UL listed device | S | un | S | un | |
| 5. Test from terminal link | S | un | S | un | |
| 6. Test from remote pull | S | un | S | un | |
| 7. Proper nozzle covers in place | S | un | S | un | |
| 8. Check travel of cable/S-hook | S | un | S | un | |
| 9. Piping/conduit securely bracketed | S | un | S | un | |
| 10. Exhaust fan operates | S | un | S | un | |
| 11. System operational & seals in place | S | un | S | un | |
| 12. Fan warning sign on hood | S | un | S | un | |
| 13. Proper Hand portable fire extinguisher | S | un | S | un | |
| 14. Filters in good condition | S | un | S | un | |
| On this date, the above system(s) was inspected in accordance with NFPA 17A, 95 and Mfg. Manuals. I have read the terms and conditions on the reverse side. | | | | | |
| DATE: _____ | | | | | |
| CUSTOMER SIGNATURE: _____ | | | | | |

(s=satisfactory, u=unsatisfactory)